

P2-4

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 64572
Permit No. 130
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35561

1. OWNER Kinross Goldbank's Mining ADDRESS AT WELL LOCATION
MAILING ADDRESS 661 Anderson St
Winnemucca NV

2. LOCATION SW 1/4 NE 1/4 Sec. 22 T. 30 N/S R. 38 E Prushing County
PERMIT NO. M/O-1105 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	349	349
Broken rock		349	353	4
Clay		353	975	622
		975	1035	60
Surface Seal		0	53	53
Grout Bentonite		53	880	827
Sand		880	1035	155

8. WELL CONSTRUCTION
Depth Drilled 1035 Feet Depth Cased 1020 Feet
HOLE DIAMETER (BIT SIZE)
From To
8 Inches 0 Feet 20 Feet
5 1/2 Inches 20 Feet 735 Feet
5 7/8 Inches 735 Feet 1035 Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
6 5/8 5/16 +2 20
1 1/4 .125 +18" 1020
Perforations:
Type perforation 5/16th rd
Size perforation .020
From 1000 feet to 1020 feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type:
Depth of Seal 53' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From _____ feet to _____ feet

Date started January 16, 1997
Date completed January 25, 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
	<u>205</u>	<u>2</u>	
	<u>325</u>	<u>12</u>	
	<u>405</u>	<u>20</u>	
	<u>605</u>	<u>20</u>	
	<u>985</u>	<u>20</u>	
	<u>995</u>	<u>75</u>	
	<u>1035</u>	<u>75</u>	

9. WATER LEVEL
Static water level 119' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ekland Drilling Co. Inc. Contractor
Address P.O. Box 2748 Contractor
Elko, NV 89803
Nevada contractor's license number #0030823
issued by the State Contractor's Board.
Nevada driller's license number issued by the 1915
Division of Water Resources, the on-site driller.
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 2-4-97