WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64586
Permit No.
Basin 072

NOTICE OF INTENT NO. 28536

1. OWNER Florida Canyon Mining
MAILING ADDRESS P. O. Box 330
Imlay, NV 89418

ADDRESS AT WELL LOCATION Florida Canyon Mine
near Imlay, NV

2. LOCATION SW ¼ NW ¼ Sec. 11 T. 31 N/S R. 33 E. Pershing County
PERMIT NO. M/o-889 A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt Stone		0	35	35
Quartz		35	45	10
Siltstone		45	260	215
Shale		260	445	185
Native fill from		380	445	65

Date started 2/2, 19 95
Date completed 2/4, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
90'	3		During drill
225	15		" "
305	27		" "
445	50		2 hr.

8. WELL CONSTRUCTION
Depth Drilled 445 Feet Depth Cased 377 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	18	Feet
5 1/2	Inches	18	Feet	445	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		1/8"	18	+2
1 1/2"		SCH 40	377	+2

Perforations:
Type perforation Horz.
Size perforation .020
From Blank 0 feet to 187 feet
From Alt Screen 10 feet to Blank 10 feet
From 187 feet to 377 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 51'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 380 feet to 86 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 89 °F Quality clean

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EKLUND DRILLING COMPANY, INC. (Contractor)
Address P. O. Box 2786 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1698
Signed Gary L. Massie (By driller performing actual drilling on site or contractor)
Date 2-16-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627