



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK.

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15827

1. OWNER ANN STRECKER ADDRESS AT WELL LOCATION 1581 EAST SANTOVITO STREET  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NW 1/4 SE 1/4 Sec. 14 T. 21-S N/S R. 53 E NYE County \_\_\_\_\_  
 PERMIT NO. 44-742-06 MESA OESTE ESTATES UNIT 2 BLOCK 13  
 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Brown clay		4	8	4
Gray clay & caliche		8	36	28
Limestone		36	40	4
Gray clay & caliche	X	40	72	32
Limestone		72	76	4
Brown clay		76	107	31
Brown clay & caliche		107	128	21
Brown clay		128	142	14
Brown clay & caliche	X	142	160	18

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
12 Inches 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	160

Perforations:  
 Type perforation Torch cut  
 Size perforation 1/4" width 8" long  
 From 120 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

9. WATER LEVEL  
 Static water level 50 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started APRIL 7, 1997  
 Date completed APRIL 7, 1997

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/2

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name JIM PIKE WELL DRILLING, LLC Contractor  
 Address P.O. BOX 56 PAHRUMP, NV 89041 Contractor

Nevada contractor's license number issued by the State Contractor's Board 17563A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812

Signed [Signature]  
 By driller performing actual drilling on site or contractor

Date APRIL 11, 1997

