

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15846

1. OWNER Jony Semeny ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Pahrump, NV 89041 \_\_\_\_\_  
 2. LOCATION SE 1/4 SW 1/4 Sec. 26 T. 20S N/S R. 52E E Nye County \_\_\_\_\_  
 PERMIT NO. 28-1001-12 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Soil		0	8	8
Brown Clay		8	30	22
Cebichia		30	33	3
Brown Clay		33	56	23
Grey Clay	X	56	106	50
Ghauch	X	106	110	4
Grey Clay	X	110	150	40
Ghauch	X	150	160	10

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1.315</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:  
 Type perforation factory  
 Size perforation 1/2 x 3/4  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 0 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

Date started Feb-28 1997  
 Date completed March 8 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>30</u>	<u>0</u>	<u>1/2</u>

9. WATER LEVEL  
 Static water level 53 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Larry Semeny Contractor  
 Address P.O. Box 3392 Contractor  
Pahrump, NV 89041  
 Nevada contractor's license number 0035901  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916  
 Signed Larry Semeny  
 By driller performing actual drilling on site or contractor  
 Date 3-10-97