

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15844

1. OWNER Robert Verce ADDRESS AT WELL LOCATION Lot 12 Comstock Parkway Pahrump, NV 89001
 MAILING ADDRESS Pahrump, NV 89001

2. LOCATION S.W. 1/4 SW 1/4 Sec. 13 T. 21S N/S R. 53E E Nye County
 PERMIT NO. 44-612-05 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Red Clay		0	6	6
Dec. Caliche		6	15	9
Grey Clay		15	35	20
Caliche		35	37	2
Grey Clay		37	55	18
Brown Clay	X	55	85	30
Grey Clay	X	85	140	55

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 1.8 Inches 0 Feet 740 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE


Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1.8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation factory
 Size perforation 1/4 x 3/4

From _____ feet to _____ feet
 From _____ feet to _____ feet
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet



9. WATER LEVEL
 Static water level 52 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

Date started 2-24-97, 19____
 Date completed 3-1-97, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>5</u>	<u>1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lump Water Well Service Contractor
 Address P.O. Box 3390 Pahrump, NV 89001 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0035901
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916

Signed Gary Jenkins
 By driller performing actual drilling on site or contractor
 Date 3-5-97