

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16203

1. OWNER Battle Mt Gold Co. ADDRESS AT WELL LOCATION CP-4  
MAILING ADDRESS Box 1627 South P-1 Pit  
Battle MT NV 89802  
2. LOCATION NW 1/4 SW 1/4 Sec 34 T. 31 S. R. 43 E. Lander County  
PERMIT NO. MO-967-A Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand &amp; clay</u>		<u>0</u>	<u>47</u>	<u>47</u>
<u>Sandy argillite</u>	<u>x</u>	<u>47</u>	<u>150</u>	<u>103</u>
<u>Sand stone</u>		<u>150</u>	<u>175</u>	<u>25</u>
<u>GRAVEL</u>		<u>175</u>	<u>185</u>	<u>10</u>
<u>Sand stone</u>		<u>185</u>	<u>430</u>	<u>245</u>
<u>Sand stone with pebbles conglomerate</u>		<u>430</u>	<u>457</u>	<u>27</u>
<u>Cemented hole back to 377</u>				
<u>NH 513350</u>				
<u>NH 5126183 100227</u>				
<u>100227</u>				

8. WELL CONSTRUCTION  
Depth Drilled 457 Feet Depth Cased 377 Feet

HOLE DIAMETER (BIT SIZE)  
From To  
9 7/8 Inches 0 Feet 50 Feet  
7 7/8 Inches 50 Feet 457 Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>Schedule</u>	<u>80 PVC</u>	<u>0</u>	<u>377</u>

Perforations:  
Type perforation 1020 Slot PVC  
Size perforation  
From 11.7 feet to 316 feet  
From feet to feet  
From feet to feet  
From feet to feet  
From feet to feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 30 feet to 377 feet

9. WATER LEVEL  
Static water level 134 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature Cold °F Quality Fair

Date started 12-7 1995  
Date completed 1-23 1996

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name AAA Drilling Co. Contractor  
Address Box 24187 Contractor  
Eiko NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020684  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1783

Signed L. R. ...  
By driller performing actual drilling on site or contractor  
Date 2-12-96