WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64635
Permit No.
Basin 072

NOTICE OF INTENT NO. 25606

1. OWNER FLORIDA CANYON MINE
MAILING ADDRESS P.O. BOX 330
IMLAY, NEVADA 89418

ADDRESS AT WELL LOCATION 1 MILE NORTH OF FLORIDA CANYON MINE

2. LOCATION NE ¼ SE ¼ Sec. 34 T. 32 N/S R. 33 E. PERSHING County
PERMIT NO. 61707 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAYS, ROCK, GRAVEL		0	120	120
SAND AND GRAVEL, ROCK		120	350	130
CEMENTED GRAVEL		350	485	135
BROKEN ROCK & GRAVEL		485	580	195
CLAYS		580	582	2

Date started 7/19/96, 19
Date completed 8/16/96, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	154	24

8. WELL CONSTRUCTION
Depth Drilled 582 Feet Depth Cased 575 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
24 Inches		0 Feet	105 Feet
12.75 Inches		105 Feet	582 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	42.05	.250	0	105
8		.250	+2	435
8		.250	565	575

Perforations:
Type perforation WIRE WRAP SCREEN STAINLESS
Size perforation 100 SLOT
From 435 feet to 565 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 105
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 582 feet

9. WATER LEVEL
Static water level 266 feet below land surface
Artesian flow --- G.P.M. P.S.I.
Water temperature 88 °F Quality FAIR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SARGENT IRRIGATION CO (Contractor)
Address 9955 NORTH VIRGINIA STREET (Contractor)
RENO, NEVADA 89506
Nevada contractor's license number issued by the State Contractor's Board 0021246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1593
Signed (By driller performing actual drilling on site or contractor)
Date 8/16/96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627