WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64637
Permit No.
Basin 059

NOTICE OF INTENT NO. 30923

1. OWNER SIERRA CHEMICAL CO.
MAILING ADDRESS 2302 LARKIN CR. SPARKS NV. 89431
ADDRESS AT WELL LOCATION SIERRA CHEMICAL CO. 523 E. FRONT ST. BATTLE MT. NV.

2. LOCATION A ¼ B ¼ Sec. 20 T. 32 N/S R. 45 E. LANDER County
PERMIT NO. COLD M/O # 782 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other ANGEL

6. LITHOLOGIC LOG MW-1

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ON 1/3/97 I. FOUND THE WELL TO BE IN GOOD CONDITION. AFTER REMOVING THE COVER, I THEN DRILLED THE 2" CASING OUT TO 20'. I THEN PRESSURE GROUTED THE ~~WHOLE~~ HOLE WITH NEAT CEMENT FROM 20' TO THE SURFACE. | | | | |

Date started 1/3, 1997
Date completed 1/3, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| N/A | | |

8. WELL CONSTRUCTION
Depth Drilled 20' Feet Depth Cased N/A Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 6" Inches | 0' Feet | 20' Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2" | SCH40 | PVC | 0' | 20' |
| | | | | |
| | | | | |

Perforations:
Type perforation FACTORY
Size perforation .020
From 5' feet to 20' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 20'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 7' feet below land surface
Artesian flow NO G.P.M. N/A P.S.I.
Water temperature COLD °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ANDRESEN EXPLORATION DRILLING (Contractor)
Address 1635 BELFORD RD. RENO, NV. 89509 (Contractor)
Nevada contractor's license number 34525 issued by the State Contractor's Board.
Nevada driller's license number 1028 issued by the Division of Water Resources, the on-site driller.
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 1/28/97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627