

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26533

1. OWNER ERREN CORTIZ ADDRESS AT WELL LOCATION None
 MAILING ADDRESS ?

2. LOCATION N.W. 1/4 NW 1/4 Sec. 7 T. 34 (N) S. 56 E. ELKO County
 PERMIT NO. _____
 Issued by Water Resources LOT 20, BLK F Parcel No. Last Chance Ranch #3 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy clay</u>		<u>0</u>	<u>19</u>	<u>19</u>
<u>Boulders</u>		<u>19</u>	<u>25</u>	<u>6</u>
<u>Gravel</u>	<u>soapy</u>	<u>25</u>	<u>26</u>	<u>1</u>
<u>Gray shale</u>		<u>26</u>	<u>228</u>	<u>202</u>
<u>Sand</u>	<u>✓</u>	<u>228</u>	<u>242</u>	<u>14</u>
<u>Shale</u>		<u>242</u>	<u>248</u>	<u>6</u>
<u>Sand</u>	<u>✓</u>	<u>248</u>	<u>256</u>	<u>8</u>
<u>Shale</u>		<u>256</u>	<u>265</u>	<u>9</u>
	<u>T.D</u>	<u>265</u>		

8. WELL CONSTRUCTION
 Depth Drilled 265 Feet Depth Cased 265 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 5.5 Feet
8 Inches 5.5 Feet 265 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.92</u>	<u>.185</u>	<u>4 1/2</u>	<u>265</u>

Perforations:
 Type perforation Torch cut
 Size perforation 1/8" x 4"
 From _____ feet to _____ feet
 From 223 feet to 260 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 265 feet

9. WATER LEVEL
 Static water level 85 ft. feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Coold °F Quality Coold

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MUTH DRILLING CO. Contractor
 Address 203 Pine St. Elko, NV 89801 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 10819
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
 Signed James Y. Muth
 By driller performing actual drilling on site or contractor
 Date 11-7-94

Date started 10-12, 1994
 Date completed 11-1, 1994

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	