WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64679
Permit No.
Basin 070

NOTICE OF INTENT NO. 35848

1. OWNER Rocky & Sandra Stull
MAILING ADDRESS HC60 Box 51193
Round Mountain, NV 89045

ADDRESS AT WELL LOCATION
#1 Phyllis Lane
Golconda, Nevada 89414

2. LOCATION SE 1/4 SW 1/4 Sec. 31 T 35 N/S R 40 E Humboldt County
PERMIT NO. _____ Issued by Water Resources | 08-601-34 Parcel No. | Lot D-4 Subdivision Name

**3. WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

**4. PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

**5. WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thick-ness |
|---|---|---|---|---|
| Clay w/Cobbles | | 0 | 4 | 4 |
| Gravel & Cobbles | | 4 | 36 | 32 |
| Clay w/Cobbles | | 36 | 81 | 45 |
| Clay | | 81 | 128 | 47 |
| Fractured Rock w/Clay | | 128 | 230 | 102 |
| Fractured Rock w/Sand | | 230 | 257 | 27 |

Date started 2/25/97 , 19__
Date completed 2/26/97 , 19__

**7. WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 25 | | 2 hr. |

**8. WELL CONSTRUCTION**
Depth Drilled 257 Feet Depth Cased 255 Feet

**HOLE DIAMETER (BIT SIZE)**

| | | From | | To | |
|---|---|---|---|---|---|
| 10 7/8 | Inches | 0 | Feet | 257 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | +1 | 255 |
| | | | | |

**Perforations:**
Type perforation Single Row Mill Slot
Size perforation 1/8" x 3"
From 215 feet to 255 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 255 feet

**9. WATER LEVEL**
Static water level 42' feet below land surface
Artesian flow 0 G.P.M. 0 P.S.I.
Water temperature Cool °F Quality Good

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
Contractor
Address 4675 West Winnemucca Blvd.
Contractor
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562

Signed [signature]
By driller performing actual drilling on-site or contractor

Date 3-10-97