

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32044

1. OWNER PERRY D. SARGENT ADDRESS AT WELL LOCATION None
 MAILING ADDRESS 137 PINE ST. ELKO, NV 89801
 2. LOCATION SE 1/4 SW 1/4 Sec. 7 T. 34 N. S. R. 56 E. ELKO County
 PERMIT NO. None Issued by Water Resources Parcel No. LOT 14 BLKE Subdivision Name LAST CHANCE RANCH UNIT #3

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil		0	4	4
Boulders, cobbles, gravel & sand w/clay		4	12	8
Tuff (Humboldt fm)		12	178	166
Sandstone, soft brown. Eiko fm	✓	178	205	27
Siltstone		205	220	15
Broken cherty limestone		220	225	5
Sandstone & Siltstone	?	225	275	50

8. WELL CONSTRUCTION
 Depth Drilled 275 Feet Depth Cased 276 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet
9 Inches 50 Feet 275 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1 1/2</u>	<u>275</u>

Perforations:
 Type perforation Mill slots & torch cut
 Size perforation
 From 167 feet to 209 Mill slots feet
 From 233 feet to 267 torch cut feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 275 feet

9. WATER LEVEL
 Static water level 173 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started 12-17, 1996
 Date completed 12-23, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>10</u>	<u>To bottom</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name MUTH DRILLING CO. Contractor
 Address 203 PINE ST. ELKO, NV 89801 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 10819
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
 Signed James V. Muth
 By driller performing actual drilling on site or contractor
 Date 12-24-96