

OFFICE USE ONLY  
 Log No. 64687  
 Permit No. 295 044  
 Basin 295 044

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35296

1. OWNER Luck Cornish ADDRESS AT WELL LOCATION Block 16 Lot 5  
 MAILING ADDRESS 403-37 406-8  
Ryaner NV  
 2. LOCATION N 1/4 SE 1/4 Sec. 5 T. 35 S. R. 57 E. E 1/4 County Twin River Ranches  
 PERMIT NO. 26016055 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>TOP soil</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>clay sand</u>		<u>2</u>	<u>91</u>	<u>89</u>
<u>Rock</u>		<u>91</u>	<u>122</u>	<u>32</u>
<u>Gravel sand</u>	<u>X</u>	<u>122</u>	<u>155</u>	<u>33</u>
<u>clay</u>		<u>155</u>	<u>160</u>	<u>5</u>

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 160  
10 Inches 0 Feet 160 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>158</u>	<u>0</u>	<u>160</u>

Perforations:  
 Type perforation FOC  
 Size perforation \_\_\_\_\_  
 From 110 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 160 feet

9. WATER LEVEL  
 Static water level 110 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started Nov - 25, 1996  
 Date completed Nov - 25, 1996

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>0</u>	<u>2</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AAA Drilling Contractor  
 Address P.O. Box 2487 Contractor  
Elko NV  
 Nevada contractor's license number issued by the State Contractor's Board 0026684  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438  
 Signed Shan Bennett  
 By driller performing actual drilling on site or contractor  
 Date Nov - 25 - 96