WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64688
Permit No.
Basin 061

NOTICE OF INTENT NO. 25775

1. OWNER Newmont Gold Co.
MAILING ADDRESS PO Box 669
Carlin NV 89822-0669

ADDRESS AT WELL LOCATION Tailings Pond, Nth Area - Newmont Gold - Rita K

2. LOCATION NE ¼ SE ¼ Sec. 11 T. 36 N/S R. 50 E EUREKA County

PERMIT NO. M/O - 864 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silicous mud Stone		0	45	45
Silicious mud Stone		45	70	25
Intrusive		70	85	15
Silicous mud Stone		85	130	45
Intrusive		130	145	15
Silicious mud Stone		145	160	15
Clay		160	165	5
Silicious mud Stone		165	520	355
Limestone		520	535	15
Silicious Mudstone		535	615	80
Limestone		615	870	255
Silicious Mudstone		870	1070	200
Limestone	145	1070	1215	145
Lime Stone	105	1215	1320	105
Silicious mud Stone		1320	1500	180
mudstone		1500	1550	50

Date started 12-7, 1997
Date completed 12-11, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1550 Feet Depth Cased 1548' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7 Inches		0 Feet	1550 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 3/8	4.60	3/8	0	1528

Perforations:
Type perforation Mill Slot
Size perforation 3/32
From 1528 feet to 1548 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 1500'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 660 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sheridan McClard
Contractor
Address HC-30 Box 102
Contractor
Elko, NV 89801
Nevada contractor's license number issued by the State Contractor's Board 0026661
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1631
Signed Sheridan McClard
By driller performing actual drilling on site or contractor
Date 1-9-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627