VD-97-23

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64695
Permit No.
Basin 061

NOTICE OF INTENT NO. 14016

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION NE ¼ SE ¼ Sec. 19 T. 36 (N) S R. 50 E. EUREKA County
PERMIT NO. 58355 Issued by Water Resources | N/A Parcel No. | N/A Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BLACK & GRAY ROCK		0	30	30
GRAY ROCK & GRAY CLAY		30	80	50
BLACK & GRAY ROCK		80	250	170
NO RETURN		250	305	55
GRAY CLAY & BLACK ROCK		305	345	40
BLACK & GREEN ROCK		345	370	25
GRAY CLAY & BLACK ROCK		370	425	55
GREEN & BLACK ROCK		425	460	35
GREEN, BLACK & GRAY ROCK		460	530	70
BLACK & GRAY ROCK		530	805	75
GRAY ROCK & GRAY CLAY		805	815	10

Date started FEBRUARY 6, 1997
Date completed FEBRUARY 10, 1997

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 815 Feet Depth Cased 802.40 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
16 Inches	0 Feet	25 Feet
98 Inches	25 Feet	815 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12-3/4	33.38	3/8	0	20
6	17.02	1/4	+1	119

Perforations:
Type perforation LOUVERED
Size perforation 1/8
From 119 feet to 815 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 20
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to SURFACE feet

9. WATER LEVEL
Static water level 387.80 feet below land surface
Artesian flow NO G.P.M. N/A P.S.I.
Water temperature 56 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING
Contractor
Address 2286 WEST 1500 SOUTH
Contractor
SALT LAKE CITY, UTAH 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2000

Signed WILLIAM EDDY William Eddy
By driller performing actual drilling on site or contractor
Date 1-30-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627