

OFFICE USE ONLY  
 Log No. 64712  
 Permit No. J45  
 Basin. J45

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34247

1. OWNER Shanel C. Fertig SA ADDRESS AT WELL LOCATION Lot 7 - Rik 39  
 MAILING ADDRESS P.O. Box 525 North McKinley Ave  
FRG NO 87803  
 2. LOCATION SW 1/4 SW 1/4 Sec 25 T. 36 N/S R. 56 E Elk County  
 PERMIT NO. 12-039-07-9 Parcel No. Rnyden Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY LOESS		0	3	3
Hard pan		3	6	3
CLAY		6	10	4
SAND STONE		10	54	44
CLAY		54	186	132
LESS SAND STONE	X	186	212	26

8. WELL CONSTRUCTION  
 Depth Drilled 212 Feet Depth Cased 212 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 212 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	1.88	12	212

Perforations:  
 Type perforation Mill slots  
 Size perforation 3/16 x 3"  
 From 192 feet to 212 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 52  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 52 feet to 212 feet

9. WATER LEVEL  
 Static water level 142 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality \_\_\_\_\_

Date started 12-12, 1996  
 Date completed 12-14, 1996

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Open</u>	<u>24</u>		<u>2.5</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Fertig Drilling Co Contractor  
 Address P.O. Box 525 Contractor  
FRG NO 87803  
 Nevada contractor's license number issued by the State Contractor's Board 31904  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1554-T1  
 Signed Shanel C. Fertig  
 By driller performing actual drilling on site or contractor  
 Date 12-29-96