WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64720
Permit No.
Basin 042

NOTICE OF INTENT NO. 33204

1. OWNER MARK MCALLISTER
MAILING ADDRESS P.O. BOX 81
WELLS, NV 89835

ADDRESS AT WELL LOCATION NORTH OF WELLS, NV NEAR TOWN OF METROPOLIS

2. LOCATION NW 1/4 NW 1/4 Sec. 29 T 39N N/S R 62E E ELKO County
PERMIT NO. (Issued by Water Resources) 08-360-19 (Parcel No.) TRACT OF LAND (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	2	2
BROWN CLAY		2	25	23
SAND & GRAVEL	X	25	60	35
BROWN CLAY		60	70	10
SAND & GRAVEL	X	70	100	30

RECEIVED 97 JAN 31 AM 10:25 STATE ENGINEER'S OFFICE

Date started 1/15/97, 19__
Date completed 1/15/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60		3

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	100	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	100

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 80 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 100 feet

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689

Signed Dave Hansen
(By driller performing actual drilling on-site or contractor)
Date 1-15-97