

OFFICE USE ONLY
 Log No. 64727
 Permit No. _____
 Basin 16a



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15524

1. OWNER Charles and Delli Sumpter ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 5630 Homestead Road 2210 W. Quail Run Road Pahrump, NV 89048
Pahrump, NV 89048

2. LOCATION NE 1/4 NE 1/4 Sec. 31 T 19S N/S R 53E E Nye County
 PERMIT NO. 29-541-31 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Loam		0	14	14
Light Brown Loam		14	29	15
Brown Clay		29	43	14
Tan Clay	x	43	59	16
Light Brown Clay	x	59	74	15
Tan Clay	x	74	95	21
Light Brown Clay	x	95	113	18
Brown Clay	x	113	140	27
Dark Brown Clay	x	140	155	15

8. WELL CONSTRUCTION
 Depth Drilled 155 Feet Depth Cased 155 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 3/4 Inches To 0 Feet 155 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE


Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>17</u>	<u>188</u>	<u>0</u>	<u>155</u>

Perforations:
 Type perforation TORCH
 Size perforation .25 x 6
 From 110 feet to 130 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 155 feet

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025
 Signed Larry Strickland
 By driller performing actual drilling on-site or contractor
 Date 4-14-97



Date started 3/31/97, 19____
 Date completed 3/31/97, 19____

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>na</u>	<u>.50</u>

