WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64728
Permit No.
Basin 162

NOTICE OF INTENT NO. 15521

1. OWNER Duncan Searle
MAILING ADDRESS P.O. Box 4000/208
Pahrump, NV 89041

ADDRESS AT WELL LOCATION
3200 Rancho Paradiso Pahrump, NV 89048

2. LOCATION SE 1/4 SW 1/4 Sec. 28 T 19S N/S R 53E E Nye County
PERMIT NO. _____ Issued by Water Resources
29-131-06 Parcel No.
Rancho Paradiso Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Loam		0	13	13
Brown Clay		13	28	15
White Clay		28	42	14
Light Brown Clay		42	65	23
Brown Clay	x	65	78	13
Brown Calichia	x	78	82	4
Brown Clay	x	82	120	38
Light Tan Clay	x	120	138	18
Light Brown Clay	x	138	160	22

DCNR/DWR Received APR 17 1997 LAS VEGAS OFFICE

Date started 4/4/97 , 19__
Date completed 4/4/97 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	na	.50

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 3/4	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	160

Perforations:
Type perforation TORCH
Size perforation .25 x 6
From 0 feet to _____ feet
From 110 feet to 152 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025

Signed Larry Strickland
By driller performing actual drilling on-site or contractor

Date 4-14-97