

OFFICE USE ONLY
 Log No. 64734
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15832

1. OWNER CONSTANCE VANEMAN ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____ 1610 EAST KEENAN WAY

2. LOCATION SW 1/4 SE 1/4 Sec. 14 T. 21-S N/S R. 53 E NYE County _____
 PERMIT NO. 44-742-12 MESA OESTE UNIT 2 BLOCK 13
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Brown clay & caliche		4	12	8
Gray clay & caliche		12	31	19
Gray clay		31	46	15
Gray clay & caliche		46	88	42
Brown clay	X	88	112	24
Brown clay & caliche		112	130	18
Limestone		130	135	5
Brown clay & caliche	X	135	150	15
Brown clay		150	160	10

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE


Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	160

Perforations:
 Type perforation Torch cut
 Size perforation 1/4" width 8" long
 From 120 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 65 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____



Date started APRIL 15 1997
 Date completed APRIL 15 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/4

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name JIM PIKE WELL DRILLING, LLC Contractor
 Address P.O. BOX 56 Contractor
PAHRUMP, NV 89041

Nevada contractor's license number issued by the State Contractor's Board 17563A
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1812

Signed [Signature]
 By driller performing actual drilling on site or contractor

Date APRIL 21, 1997