

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 64736  
 Permit No. \_\_\_\_\_  
 Basin Q12

NOTICE OF INTENT NO. 15319

1. OWNER Vince Pastorell ADDRESS AT WELL LOCATION S.W. corner Ford & Castlewood L.V.  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NE 1/4 NE 1/4 Sec. 24 T. 22 N. R. 60 E CLARK County  
 PERMIT NO. 17624-501-041 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY + GRAVEL		0	25	25
CEMENT GRAVEL		25	60	35
CLAY + GRAVEL		60	90	30
CEMENTED GRAVEL		90	140	50
CLAY + BOULDERS		140	230	90
CEMENTED GRAVEL	MIN.	230	270	40
CLAY + BOULDERS		270	315	45
PARTIAL CEMENTED GRAVEL		315	330	15
CLAY W/ LAYERS GRAVEL	X	330	380	50

8. WELL CONSTRUCTION  
 Depth Drilled 380 Feet Depth Cased 380 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
12 1/4 Inches 0 Feet 380 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>		<u>.188</u>	<u>+1 1/2</u>	<u>380</u>

Perforations:  
 Type perforation Tool  
 Size perforation \_\_\_\_\_  
 From 300 feet to 380 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 380 feet

9. WATER LEVEL  
 Static water level 265 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality OK

Date started 3-18 1997  
 Date completed 3-25 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40</u>	<u>TOTAL 380</u>	<u>3 hrs</u>
	<u>450 CFM @ 250 PSI @ 380</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Mitchell Enterprises Contractor  
 Address 4250 So. Arville #262 Las Vegas, NV. 89103 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0042266  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1617  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 3/28/97

