

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **15480**

1. OWNER NINA BARBIERA ADDRESS AT WELL LOCATION LAVA + PAUTE SANDY VALLEY NV  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SE 1/4 SW 1/4 NW 1/4 Sec. 25 T. 24 N. R. 56 E. CLARK County  
 PERMIT NO. 1580-230-029 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	6	6
CALICHE		6	10	4
CLAY		10	28	18
CALICHE		28	38	10
CLAY		38	56	18
CALICHE		56	61	5
CLAY		61	77	16
CALICHE		77	80	3
CLAY		80	91	11
CALICHE	W.B	91	103	12
CLAY		103	118	15
CALICHE	W.B	118	126	8
CLAY		126	134	8
CALICHE	W.B	134	140	6

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation FACTORY SAW CUT  
 Size perforation 1/2 INCH BY 3 INCH  
 From 140 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 140 feet to 50 feet

9. WATER LEVEL  
 Static water level 78 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_  
 Water temperature COOL °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name BUDGET DRILLING CO. Contractor  
 Address P.O. Box 3505 Contractor  
PARTRUMP NV. 89041  
 Nevada contractor's license number issued by the State Contractor's Board 40020  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
 Signed Amie Brown  
 By driller performing actual drilling on site or contractor  
 Date 4-21-97

Date started 4-17, 1997  
 Date completed 4-19, 1997

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

