

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15229

1. OWNER Coary Hanna Nissan ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3250 East Sahara Ave Las Vegas, NV 89104 ADDRESS AT WELL LOCATION 3250 East Sahara Ave Las Vegas, NV 89104
 2. LOCATION SE 1/4 SE 1/4 Sec. 1 T 21 N0 R. 6. E Clark County
 PERMIT NO. NA 162-01-801-017 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG mw-2

Material	Water Strata	From	To	Thickness
Asphalt		0.0	0.15	0.15'
Fill		0.15	0.50	0.35'
Sandy clay		0.50	3.0	2.5'
Clay with sand		3.0	4.0	1.0'
Caliche		4.0	5.0	1.0'
Clay with silt	6.97	5.0	8.0	3.0'
Clay with sand		8.0	12.5	4.5'
Clay - reddish brown		12.5	14.5	2.0'

8. WELL CONSTRUCTION
 Depth Drilled 14.5 Feet Depth Cascd. 13.63 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
8 Inches 0 Feet 14.5 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>0.70</u>	<u>0.31</u>	<u>0</u>	<u>13.63</u>

Perforations:
 Type perforation factory slotted
 Size perforation 0.010 inch
 From 3.60 feet to 13.08 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 1.4 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 2.4 feet to 14.5 feet

9. WATER LEVEL
 Static water level: 6.97 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 4/12 1997
 Date completed 4/12 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Western Technologies Contractor
 Address 3611 W. Tompkins Ave Contractor
Las Vegas, NV 89103
 Nevada contractor's license number _____
 issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1761
 Signed _____
 By driller performing actual drilling on site or contractor
 Date _____

