WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

1 Book

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 64780
Permit No.
Basin 170

1. OWNER D.C. Day ADDRESS Alamo Nev

2. LOCATION NW ¼ SW ¼ Sec. 36 T. 3 S R. 55 E. Lincoln County
PERMIT NO. Rachel M.D.+M.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	12	12
Hard Pan		12	18	6
Sand. Gravel-Speck of Clay		18	88	70
Water Sand		88	115	27
Hard-Rock		115	135	20
Sand-Rock		135	148	13
Water Sand		148	172	24
Hard Pan		172	178	2

RECEIVED
MAY 18 1979
Div. of Water Resources
Area Office — Las Vegas, Nev.

Date started 4-7, 1979
Date completed 4-9, 1979

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 120 Draw down none feet 3 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 15 inches Total depth 172 feet
Casing record
Weight per foot Thickness 188

Diameter	From	To
8 inches	0 feet	172 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 172 feet

Perforations:
Type perforation Cut
Size perforation 1/8 x 1'
From 72 feet to 172 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 76 Feet below land surface 76
Flow G.P.M.
Water temperature Cold F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name C. M. Robinson Jr
Address Box 20 Hiko Nev
Nevada contractor's license number 10791
Nevada driller's license number 904
Signed C. M. Robinson Jr
Date 4-9-79

USE ADDITIONAL SHEETS IF NECESSARY

5471