WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64787
Permit No.
Basin 212

NOTICE OF INTENT NO. 16830

1. OWNER MH, Inc.
MAILING ADDRESS 3 Shadow Creek Drive
N. Las Vegas, NV 89031

ADDRESS AT WELL LOCATION Same

2. LOCATION SW ¼ NW ¼ Sec. 36 T 19 X N/S R 61 E Clark County
PERMIT NO. 62820T (Issued by Water Resources) | 124-36-110-003 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt, Gravel, Boulders		0	34	34
Tan clay, Gravel		34	55	21
Red sandy clay		55	195	140
Red sandy clay with small gravels		195	480	285
Red clay-some gravel		480	487	7
Course sand		487	510	23
Red sandy clay with green clay stringers		510	540	30

Date started 3/14/97, 19 97
Date completed 4/21, 19 97

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
continuous	360	66	72

8. WELL CONSTRUCTION
Depth Drilled 540 Feet Depth Cased 520 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
30 Inches		0 Feet	50 Feet
22 Inches		50 Feet	540 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
24	63.41	.250	+1	50
16	52.36	.312	+2	39
12 3/4	43.77	.330	39	520

Perforations:
Type perforation Johnson Wirewrap screen
Size perforation .060
From 160 feet to 320 feet
From 360 feet to 500 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 540 feet

9. WATER LEVEL
Static water level: 68' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Thompson Drilling Co., Inc. (Contractor)
Address 4185 W. Harmon, Las Vegas, NV 89103 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board: 4286A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1851
Signed Richard K. Thompson (By driller performing actual drilling on site of contractor)
Date 4/24/97

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627