WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64807
Permit No.
Basin 212

NOTICE OF INTENT NO. 17263

1. OWNER USAF Environmental Management Directorate
MAILING ADDRESS 4349 Duffer Dr., Suite 1100, Nellis AFB, NV 89191-7007
ADDRESS AT WELL LOCATION Nellis AFB site 44

2. LOCATION NE ¼ NW ¼ Sec. 3 T. 20 N/S R. 62 E. Clark County
PERMIT NO. MO-2780 Issued by Water Resources
140-~~10~~-10-101001 Parcel No.
N/A Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	6"	6"
Roadbase		6"	2'	1'6"
Silty Sand w/ gravel		2'	8'	6'
Silty Sand		8'	16'	8'
Brownish clay		16'	46'	30'
light Brownish clay		46'	67	21'

Date started February 27, 1997
Date completed February 28, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 67 Feet Depth Cased 67 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	67 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4¼		1/8	0	43
4¼		1/8	48	51
4¼		1/8	56	61

Perforations:
Type perforation Cont. Slot Screen
Size perforation .010
From 51 feet to 66 feet
From 43 feet to 48 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 37
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 40' to 48' feet to 50' to 66' feet

9. WATER LEVEL
Static water level 45' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Weber Drilling Services (Contractor)
Address 115 S. Weber Dr. Ste 1 (Contractor)
Chandler AZ 85226
Nevada contractor's license number issued by the State Contractor's Board 39528
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2057
Signed B Johnson (By driller performing actual drilling on site or contractor)
Date 4-12-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627