


Log No. 64808
 Permit No. _____
 Basin. 212



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17263

1. OWNER USAF Environmental Management Directorate ADDRESS AT WELL LOCATION Nellis AFB site 44
 MAILING ADDRESS 4349 Duffer Dr. Suite 1601
Nellis AFB, NV 89191-7007

2. LOCATION NE 1/4 NW 1/4 Sec. 3 T. 20 N. R. 62 E. CLARK County
 PERMIT NO. HO-2780 Issued by Water Resources Parcel No. 140-10-101-001 n/a Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0	6"	6"
Roadbase		6"	2'	1'6"
Silty sand w/ gravel		2'	8'	6'
Silty sand		8'	16'	8'
Brownish clay		16'	46'	30'
light Brownish clay		46'	67'	21'
Brownish clay		67'	89'	22'

8. WELL CONSTRUCTION
 Depth Drilled 89 Feet Depth Cascd 89 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 89 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4 1/4		1/8	0	43
4 1/4		1/8	48	53
4 1/4		1/8	63	78

Perforations:
 Type perforation Cont. Slot Screen
 Size perforation 1.020 + 0.010
 From (020) 43 feet to 48 feet
 From (010) 53 feet to 63 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 37 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 40 to 49 feet to 51 to 64 feet

9. WATER LEVEL
 Static water level: 45 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started February 25, 1997
 Date completed February 26, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Weber Drilling Services Contractor
 Address 115 S. Weber Dr. Stel Chandler AZ 85226 Contractor
 Nevada contractor's license number 39528 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2057
 Signed B. Johnson By driller performing actual drilling on site or contractor
 Date 4-12-97