


OFFICE USE ONLY
 Log No. 64830
 Permit No. _____
 Basin 212

 16491

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER LAS VEGAS SANDS, INC ADDRESS AT WELL LOCATION SANDS-VENETIAN PROJECT
 MAILING ADDRESS 3355 LAS VEGAS BLVD. SOUTH
LAS VEGAS, NV 89109
 2. LOCATION 1/4 W 1/2 Sec. 16 T. T21 N/S R. 61 E CLARK County
 PERMIT NO. DW-1065 162-16301-001-001 DEWATERING WELLS
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED DEWATER
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other AUGER

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------------|--------------|------|----|------------|
| DIRT, SAND, | | 0 | 6 | 6 |
| CALICHE | | 6 | 8 | 2 |
| SAND & ROCK & CALICHE | | 8 | 12 | 4 |
| MOIST SAND & ROCK | Y | 12 | 16 | 4 |
| WET CLAY W/GRAVEL | | 16 | 20 | 4 |
| RED CLAY | | 20 | 23 | 3 |
| CALICHE | | 23 | 27 | 4 |
| STIFF CLAY | | 27 | 40 | 13 |
| CLAY & ROCK | | 40 | 42 | 2 |

WELL 13

8. WELL CONSTRUCTION
 Depth Drilled 42' Feet Depth Cased 42' Feet
 HOLE DIAMETER (BIT SIZE)
 From To
24" Inches 0 Feet 42' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 14 | 36.71 | 1.250 | 0 | 42' |

Perforations: Factory
 Type perforation _____
 Size perforation 1/4" x 2 1/2" x 3 rows @ 13
 From 20 feet to 42' feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal N/A Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 0 feet to 42' feet

9. WATER LEVEL
 Static water level 15' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ALLEN DRILLING INC.
 Address 4847 S. VALLEY VIEW
LAS VEGAS, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board 18917
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1376
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date APRIL 21, 97

Date started APRIL 18 1997
 Date completed APRIL 21 1997

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |
| | | | |
| | | | |
| | | | |