

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32185

1. OWNER NORM NOBLE ADDRESS AT WELL LOCATION 177 LEWALLEN LAVE
 MAILING ADDRESS 607 ZUNI ST GARDNERVILLE, NV 89423
SOUTH LAKE TAHOE, CA 96150
 2. LOCATION NW 1/4 NE 1/4 Sec 25 T. 26/2 S. R. 19 E. DOUGLAS County
 PERMIT NO. 19 300 63 Issued by Water Resources Parcel No. _____ Subdivision Name NONE

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GLACIAL OUTWASH		0	40	40
REWORKED MORAIN				
MANY BLORS				
GRVL W BLK		40	75	35
SAUDS				
BLK VOL W AD	X	75	95	20
QTZ				
BLK VOL, HARD		95	105	10
FRACS				
BASALT? MAYBE		105	110	5
GRVL, VOL & MORAIN		110	120	10
DEBRIS				
FE STAINED	X	120	140	20
GRVL				
OLDER MORAIN		140	240	100
DEBRIS W AB				
BASALT(?) OR RHYOLITE				
SAME, MORE VOL		240	295	55
V HARD				
V HARD BLK VOL		295	300	5

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 300 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>		<u>.188</u>	<u>+2</u>	<u>300</u>

Perforations:
 Type perforation SAWCUT
 Size perforation 3x 3/32
 From 160 feet to 300 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 51
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 51 feet to 300 feet

9. WATER LEVEL
 Static water level 76 feet below land surface
 Artesian flow No G.P.M. _____ P.S.I. _____
 Water temperature COLD °F Quality _____

Date started 12/12, 1996
 Date completed 12/18, 1996

7. WELL TEST DATA

TEST METHOD	Bailer	Pump	Air Lift
<u>100</u> G.P.M.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
	Draw Down (Feet Below Static)	Time (Hours)	
		<u>3</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA DRILLING, INC Contractor
 Address 75 LEWERS CRK RD Contractor
CARSON CITY, NV 89704
 Nevada contractor's license number issued by the State Contractor's Board 13697A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1476
 Signed Joe Reisk
 By driller performing actual drilling on site or contractor
 Date 1/28/97