

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32941
ADDRESS AT WELL LOCATION 126 Pete Hendricks
Yerington, NV 89447

1. OWNER Joe Landolt ADDRESS AT WELL LOCATION 126 Pete Hendricks
MAILING ADDRESS 120 Manha Lane Yerington, NV 89447
2. LOCATION NE 1/4 NE 1/4 Sec. 6 T. 13 N. S. R. 26 East Lyon County
PERMIT NO. 14-551-03 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand Fine		0	20	20
Multi Colored gravel Round	X	20	50	30
Multi Colored Course Sand Soft	X	50	135	85
T.D. 135'				

8. WELL CONSTRUCTION
Depth Drilled 135 Feet Depth Cased 135 Feet
HOLE DIAMETER (BIT SIZE)
From 10 5/8 Inches To 0 Feet 135 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.92</u>	<u>.188</u>	<u>+1 1/2</u>	<u>135</u>

Perforations:
Type perforation Johnson Well Screen
Size perforation .030 Slot
From 1.05 feet to 1.15 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 135 feet to 50 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality _____

Date started February 6, 1997
Date completed February 10, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20+</u>		<u>2 Hours</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A.S.A.P. Pump & Well Service, Inc. Contractor
Address 1800 1/2 Frazer Ave. Contractor
Sparks, NV 89431
Nevada contractor's license number XXXXX 35387-A issued by the State Contractor's Board
Nevada driller's license number issued by the 1509 Division of Water Resources, the on-site driller.
Signed [Signature]
By driller performing actual drilling on site or contractor
Date February 10, 1997