WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

# STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64862
Permit No.
Basin 102

NOTICE OF INTENT NO. 34383

1. OWNER Bryce Jones
MAILING ADDRESS P.O. Box 3366
Truckee, CA 96160

ADDRESS AT WELL LOCATION
5035 Geraldine Lane, Silver Springs, NV 89429

2. LOCATION SE 1/4 SE 1/4 Sec. 32 T 18N N/S R 24E E Churchill County
PERMIT NO. (Issued by Water Resources) | Parcel No. 18-465-10 | Subdivision Name

**3. WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

**4. PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

**5. WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 10 | 10 |
| Brown Clay | | 10 | 150 | 140 |
| Sand & Gravel | | 150 | 170 | 20 |
| Sandy Clay | | 170 | 290 | 120 |
| Gravel | | 290 | 330 | 40 |
| Sandy Clay | | 330 | 440 | 110 |
| Gravel & Sand | X | 440 | 455 | 15 |

Date started August 20, 1996
Date completed August 22, 1996

**7. WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

**8. WELL CONSTRUCTION**
Depth Drilled 455 Feet Depth Cased 455 Feet

**HOLE DIAMETER (BIT SIZE)**

| | | From | To |
|---|---|---|---|
| 10 Inches | | 0 Feet | 455 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.92 | .188 | 0 | 455 |
| | | | | |
| | | | | |

**Perforations:**
Type perforation mill cut
Size perforation 1/8"
From 435 feet to 455 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 455 feet

**9. WATER LEVEL**
Static water level 336 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 11-15-96