WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64864
Permit No.
Basin 101
NOTICE OF INTENT NO. 34908

1. OWNER Vernon Lambson
MAILING ADDRESS P.O. Box 1063
Fallon, NV 89407-1063

ADDRESS AT WELL LOCATION
920 Lazy Heart Ln., Fallon, Nv. 89406

2. LOCATION NW 1/4 NE 1/4 Sec. 18 T 18N N/S R 29E E Churchill County
PERMIT NO. (Issued by Water Resources) | Parcel No. 006-751-50 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	12	12
Brown Clay		12	18	6
Brown Sandy Clay		18	23	5
Light Brown Clay		23	28	5
Brown Sand		28	38	10
Black Sandy Clay		38	46	8
Black Sand		46	68	22
Black Clay		68	82	14
Gray Black Sand		82	93	11
Green Clay		93	94	1
Gray Sand & Gravel		94	110	16
Green Clay		110	115	5
Gray Sand		115	123	8
Brown Clay		123	125	2
Brown Sand		125	135	10

RECEIVED JUN -9 AM 11:10 STATE ENGINEER'S OFFICE

Date started 11/21/96, 19__
Date completed 11/21/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 135 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10in.	Inches	0	Feet	135	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	135

Perforations:
Type perforation mill cut
Size perforation 3/8 inch
From 130 feet to 135 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 ft.
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 135 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 1-2-97