WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64868
Permit No.
Basin 171
NOTICE OF INTENT No. 34334

1. OWNER DIVERSIFIED BUILDERS
MAILING ADDRESS 4888 RENO HWY
FALLON, NV 89406

ADDRESS AT WELL LOCATION
5076 RIVER'S EDGE

2. LOCATION SW 1/4 SW 1/4 Sec. 28 T 19N N/S R 28E E CHURCHILL County
PERMIT NO. Issued by Water Resources | 208-492-45 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	20	20
BROWN CLAY		20	22	2
BROWN SAND		22	30	8
GREY SAND		30	50	20
BLACK SILT		50	73	23
GREY SAND		73	80	7
BROWN SAND		80	90	10
BROWN CLAY		90	93	3
GREY CLAY		93	119	26
GREY CLAY		119	122	3
BROWN SAND	X	122	136	14

Date started 8/15/96, 19__
Date completed 8/15/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 136 Feet Depth Cased 136 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6 5/8	Inches	50	Feet	136	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	136

Perforations:
Type perforation MACHINE SLIT
Size perforation .080
From 125 feet to 133 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 13.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp. (Contractor)
Address 305 E. WILLIAMS AVE. P. O. BOX 888 (Contractor)
FALLON, NV 89407

Nevada contractor's license number issued by the State Contractor's Board 11752

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996

Signed
By driller performing actual drilling on-site or contractor

Date 8-27-96