

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. 64869  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 30047

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Bill Ford ADDRESS AT WELL LOCATION 3695 Alcorn Rd. Fallon, Nv. 89406  
 MAILING ADDRESS 3695 Alcorn Rd. Fallon, NV 89406

2. LOCATION NW 1/4 NW 1/4 Sec. 34 T 19 N/S R 28E E Churchill County  
 PERMIT NO. 008-752-21 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	4
Brown Sand		4	10	6
Brown Clay		10	16	6
Brown Sand		16	40	24
Black Clay		40	42	2
Grey Sand		42	76	34
Brown Clay		76	77	1
Brown Sand		77	83	6
Brown Clay	xxx	83	84	1

8. WELL CONSTRUCTION  
 Depth Drilled 84 Feet Depth Cased 84 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 84 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	84

Perforations:  
 Type perforation Mill-Cut  
 Size perforation 1/8"  
 From 81 feet to 84 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 84 feet

Date started 11/19/96, 19\_\_\_\_  
 Date completed 11/19/96, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD: G.P.M.	TEST METHOD:		Time (Hours)
	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	
	Draw Down (Feet Below Static)	<input checked="" type="checkbox"/> Air Lift	

9. WATER LEVEL  
 Static water level 6 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Parsons Drilling, Inc. Contractor  
 Address P.O. Box 1265 Contractor  
Fallon, NV 89407-1265  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753  
 Signed Wayne Lewis  
 By driller performing actual drilling on-site or contractor  
 Date 1-2-97

RECEIVED  
 97 JAN -9 AM 11:12  
 STATE ENGINEERS OFFICE