

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 2913

PRINT OR TYPE ONLY

1. OWNER JOSEPH L. PACE, M.D. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 44 W. 300 S., Suite 2005-S
Salt Lake City, UT. 84101 Spanish Springs
 2. LOCATION SE 1/4 NW 1/4 Sec 25 T. 20N N/S R. 20 E Washoe County
 PERMIT NO. _____ Spanish Springs
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil, boulders mixed with clay		0	10	10
Brown volcanic rock		10	34	24
Purple volcanic rock		34	40	6
Red clay		40	62	22
Brown volcanic rock		62	165	103
White, green, red brown clay		165	225	60
Black volcanic rock		225	284	59
Blue green clay		284	311	35
Green hard volcanic rock		311	335	24
Fracture	X	335	340	5
Brown volcanic rock		340	355	5
Gray volcanic rock		355	370	25
Brown volcanic rock		370	390	20
Green volcanic rock		390	410	20
Blue volcanic rock		410	438	28
Fracture rock	X	438	440	2
Black rock Fracture	X	440	451	11
Black hard rock		451	455	4

NOTE: Water Strata (335-340) \rightarrow 30 GPM
 " " (438-440) \rightarrow 30 GPM
 " " (440-451) 120 GPM

Date started 8-16-83, 19____
 Date completed 8-19-83, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

8. WELL CONSTRUCTION
 Diameter hole 10 x 6 inches Total depth 455 feet
 Casing record 455
 Weight per foot _____ Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>455</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement
 Depth of seal _____ 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ 50 feet to _____ 455 feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 2-1/2 x 6 around
 From _____ 328 feet to _____ 348 feet
 From _____ 408 feet to _____ 448 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 238 feet below land surface
 Flow 150 G.P.M. _____ P.S.I.
 Water temperature cold ° F. Quality clear

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
 Contractor
 Address P.O. Box 12370, Reno, Nevada 89510
 Contractor
 Nevada contractor's license number 14043
 Nevada contractor's drillers number 928
 Nevada driller's license number 923
 Actual Driller
 Signed Gary C. Hedman
 Contractor
 Date August, 22, 1983