

OFFICE USE ONLY  
 Log No. 64874  
 Permit No. 085  
 Basin                     

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30641

1. OWNER JAMES MADDING ADDRESS AT WELL LOCATION Same  
 MAILING ADDRESS 343 Campo Rico Crt.  
Reno, Nevada 89510  
 2. LOCATION NW 1/4 SE 1/4 Sec. 1 T 21N N/S R. 20 E Washoe County  
Palomono Valley  
 PERMIT NO. 076-281-18 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Brown clay w/boulder and gravels		3	17	14
Brown clay		17	27	10
Rusty brown clay		27	33	6
Brown clay		33	60	27
White clay		60	112	52
Brown volcanic rock		112	145	32
White volcanic rock		145	171	26
Yellow volcanic rock		171	217	46
Rusty brown volcanic rock		217	233	16
Gray broken fractures rock	X	233	294	61
Black basalt		294	300	6

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 300 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
8 5/8 Inches 50 Feet 300 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	300

Perforations: factory sawed slot  
 Type perforation  
 Size perforation 3/32 x 3 x 5 around  
 From 232 feet to 292 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 feet  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 300 feet

9. WATER LEVEL  
 Static water level 217 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25 P.S.I.  
 Water temperature cold °F Quality clear

Date started 8-1-96, 19\_\_\_\_\_  
 Date completed 8-2-96, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources 923  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date August 5, 1996