

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31881

1. OWNER John Phillips
 MAILING ADDRESS 5705 Tanbery #B
Sun Valley, Nevada 89433
 ADDRESS AT WELL LOCATION 11600 Campo Rico
Sparks, Nevada 89436
 2. LOCATION NE 1/4 SE 1/4 Sec. 14 T. 21N N/S R. 20 East Washoe County
 PERMIT NO. 76-360-69
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown D.G.		0	20	
Brown D.G. & Clean Quartz Rock		20	145	
Brown D.G. & White Quartz Course Sands		145	250	
T.D. 250				

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 245 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10-5/8 Inches 0 Feet 70 Feet
8-1/2 Inches 70 Feet 250 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13.92	.188	1-1/2	245

Perforations:
 Type perforation Factory Sawn
 Size perforation 3/32 X 3
 From 245 feet to 225 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 245 feet to 50 feet

9. WATER LEVEL
 Static water level 150 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started February 8 1996
 Date completed February 9 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>8 hours</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A.S.A.P. Pump & Well Service, Inc.
 Contractor
 Address 1800 1/2 Frazer Ave
 Contractor
Sparks, Nevada 89431
 Nevada contractor's license number issued by the State Contractor's Board 35387-A
 Nevada driller's license number issued by the Division of Water Resources, the onsite driller 1509
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date February 12, 1996