

OFFICE USE ONLY
 Log No. 64278
 Permit No. 085
 Basin ✓
 NOTICE OF INTENT NO. 30639

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER MICHAEL BARNETT ADDRESS AT WELL LOCATION Camino De Grato
 MAILING ADDRESS 525 Mogul Mtn, Drive Reno, Nevada 89510
 Reno, Nevada 89523

2. LOCATION SE 1/4 SW 1/4 Sec. 24 T 21N N/S R. 20 E Washoe County
 PERMIT NO. 076-400-63 Spanish Springs
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other

4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay w/gravels		1	5	4
Sand & gravel		5	7	2
Brown sandy clay with gravels		7	69	62
Brown clay		69	77	8
Brown clay w/volcanic boulder & gravels		77	139	62
Brown clay		139	191	52
Brown sandy clay		191	205	14
Soft zone, SAND		205	215	10
Weathered granite		215	261	46
Soft zone (appx 6 GPM)	X	261	271	10
Weathered granite		271	281	10
Soft zone (NO WATER)		281	284	3
Weathered granite		284	315	31
Soft zone (NO WATER)		315	318	3
Weathered granite		318	358	40
Soft zone (NO WATER)		358	364	6
Weathered granite		364	379	15
White hard granite		379	387	8
Fracture (NO WATER)		387	388	1
White hard granite		388	400	12

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 100 Feet
8 5/8 Inches 100 Feet 400 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	400

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 393 feet to 373 feet
 From 353 feet to 333 feet
 From 313 feet to 293 feet
 From 273 feet to 253 feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 100 feet
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 400 feet

9. WATER LEVEL
 Static water level 163 feet below land surface
 Artesian flow 6 G.P.M. 6 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources on-site driller 923
 Signed [Signature] driller performing actual drilling on site or contractor
 Date August 5, 1996

Date started 7-29-96, 19
 Date completed 7-31-96, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>6</u>		