

OFFICE USE ONLY  
 Log No. 64882  
 Permit No. 085  
 Basin 085

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33223

1. OWNER Perry & Renee Burch ADDRESS AT WELL LOCATION 585 Eliza Ct.  
 MAILING ADDRESS 585 Eliza Ct. Sparks, NV 89436  
 2. LOCATION 42W 1/4 NE 1/4 Sec. 19 T. 21 S. R. 21 EAST WASHOE County  
 PERMIT NO. 076-371-32 372-06 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown D.G.		0	15	
White Sand		15	25	
White quartz rock & white sand		25	50	
White & orange quartz rock		50	65	
Black Granite soft		65	200	
Hard black & white granite		200	245	
Weathered white & black granite soft		245	275	
White & black granite hard		275	300	
White & black granite fractured		300	433	
Weathered white & black granite soft	X	433	520	
White & black granite hard		520	545	
White & black granite		545	730	
Fractured hard & soft white & black granite	X	730	751	

8. WELL CONSTRUCTION  
 Depth Drilled 751 Feet Depth Cased 751 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
1.0-5/8 Inches 0 Feet 50 Feet  
8-1/2 Inches 50 Feet 751 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13.92	.188	-1 1/2	751

Perforations:  
 Type perforation Factory Sawn  
 Size perforation 3/32 x 3  
 From 751 feet to 731 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 751 feet to 50 feet

9. WATER LEVEL  
 Static water level 425' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.S.A.P. Pump & Well Service Inc. Contractor  
 Address 1800 1/2 Frazer Avenue Contractor  
Sparks NV 89431  
 Nevada contractor's license number issued by the State Contractor's Board 35387-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509T-1  
 Signed Tammy Welch  
 By driller performing actual drilling on site or contractor  
 Date August 30, 1996

Date started August 14, 1996  
 Date completed August 29, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>		<u>3 hours</u>

RECEIVED  
 AUG 29 11 12 AM '96  
 DIVISION OF WATER RESOURCES