

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 31572

1. OWNER Rick Gisler ADDRESS AT WELL LOCATION 1200 Mineral Flat Road  
 MAILING ADDRESS 1200 Mineral Flat Road Reno, Nevada 89506  
 Reno Nevada 89506  
 2. LOCATION SE 1/4 NE 1/4 Sec. 1422 T. 22 S. 19 East Washoe County  
 PERMIT NO. 079-480-4722 Parcel No. Red Rock Estates # 256, Parcel 1 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown D.G.		0	20	
Brown Clay		20	40	
Multi colored volcanic rock		40	60	
Salt & Pepper Granite		60	195	
T.D. 195'				

8. WELL CONSTRUCTION  
 Depth Drilled 195 Feet Depth Cased 195 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
 10 5/8 Inches 0 Feet 50 Feet  
 8 1/2 Inches 50 Feet 195 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.92	-188	1 1/2	195

 Perforations:  
 Type perforation Factory Sawn  
 Size perforation 3/32 x 3  
 From 185 feet to 165 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 195' feet to 50' feet

Date started June 5, 19 96  
 Date completed June 11, 19 96

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>2 hrs</u>

9. WATER LEVEL  
 Static water level 120' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.S.A.P. Pump & Well Service Inc. Contractor  
 Address 1800 1/2 Frazer Avenue Contractor  
Sparks, Nevada 89431  
 Nevada contractor's license number 35 387-A  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 1509T-1  
 Division of Water Resources, the on-site driller.  
 Signed Randy Welch  
 By driller performing actual drilling on site or contractor  
 Date June 12, 1996