WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64870
Permit No.
Basin 013

NOTICE OF INTENT NO. 32593

1. OWNER Harvey Nelson
MAILING ADDRESS 10640 Birch
Reno, NV. 89506

ADDRESS AT WELL LOCATION 1345 Antelope Valley Rd.
Reno, NV. 89506

2. LOCATION NW ¼ SE NE ¼ Sec. 27 T. 22N N/S R. 19E E. Washoe County
PERMIT NO. 049-051-66 Issued by Water Resources
Parcel No. 076-250-77
Red Rock (Antelope Valley) Estates #315 por 2
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
D.G.		2	29	27
Gray Hard Granite		29	88	59
Fracture (no water)		88	89	1
Gray Granite		89	146	57
Weathered Softer Granite		146	169	23
Granite, Gray		169	270	101
Soft Zone (no water)		270	273	3
Gray Granite		273	310	37
White Granite Hard		310	369	59
Gray Granite		369	436	67
Soft Zone	X	436	446	10
Weathered Granite		446	456	10
Soft Zone	X	456	478	22
Weathered Granite		478	500	22

Date started 4-4-96, 19
Date completed 4-9-96, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12		

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	500 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	500

Perforations:
Type perforation Factory sawed slot
Size perforation 3/32 x 3 x 5 around
From feet to feet
From 435 feet to 495 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 500 feet

9. WATER LEVEL
Static water level 424 feet below land surface
Artesian flow G.P.M. 12 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor
Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed Harry G. Hickman
By driller performing actual drilling on site or contractor

Date April 10, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627