WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64891
Permit No.
Basin 093

NOTICE OF INTENT NO. 34189

1. OWNER JOHN COOK
MAILING ADDRESS 216 Lemmon Drive, #206
Reno, Nevada 89506

ADDRESS AT WELL LOCATION
Alum Rock Crt.
Reno, Nevada 89506

2. LOCATION SE ¼ NW ¼ Sec. 11 T. 22N N/S R. 19 E. Washoe County
PERMIT NO. Issued by Water Resources
079-500-30 Parcel No.
Antelope Valley Red Rock Estates #233 part 1 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Sandy brown clay		3	12	9
Decomposed granite		12	54	42
Broken gray granite		54	69	15
Gray, green granite		69	106	37
Weathered soft granite (clays)		106	111	5
Weathered granite		111	131	20
Soft zone (NO WATER)		131	134	3
Weathered granite, rusty		134	140	6
Gray granite		140	153	13
Softer granite		153	173	20
Broken fracture granite	X	173	218	45
Gray granite		218	225	7

Date started 12-18-96, 19
Date completed 12-19-96, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35+		

8. WELL CONSTRUCTION
Depth Drilled 225 Feet Depth Cased 225 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
8 5/8	Inches	50	Feet	225	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	225

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 180 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 53 feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 53 feet to 225 feet

9. WATER LEVEL
Static water level 153 feet below land surface
Artesian flow G.P.M. 35+ P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. Contractor
Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] By driller performing actual drilling on site or contractor
Date December 30, 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627