WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64895
Permit No.
Basin 099

NOTICE OF INTENT NO. 31467

1. OWNER MARI GILBERT
MAILING ADDRESS 105 GYN
ADDRESS AT WELL LOCATION 105 GYM CANA LANE

2. LOCATION NE 1/4 SE 1/4 Sec. 4 T. 23 N/S R. 18 E. WASHOE County
PERMIT NO. 005582 (Issued by Water Resources) 07828905 (Parcel No.) RANCHO HAVEN (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SANDY LOAM		0	3	3
BROWN HARD PAN		3	12	9
BROWN SANDY CLAY		12	17	5
BROWN SAND		17	26	9
SANDY CLAY		26	100	74
LAYER ROUND ROCKS		100	106	6
SANDY BROWN CLAY		106	122	16
BROWN D.G.		122	160	38
GRAY SOLID GRANITE		160	225	65

Date started 4-2, 1996
Date completed 4-8, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10+		1 HR

8. WELL CONSTRUCTION
Depth Drilled 225 Feet Depth Cased 225 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	60 Feet
8 5/8 Inches	60 Feet	225 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	16	188	+1	225

Perforations:
Type perforation SACKTORY SLOT
Size perforation 3X1/8
From 140 feet to 160 feet
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 130 feet to 225 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JM DRILLING (Contractor)
Address 1859 HYMER AVE (Contractor)
SPARKS N.V. 89431
Nevada contractor's license number issued by the State Contractor's Board 41172
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1940
Signed David E. Glander
By driller performing actual drilling on site or contractor
Date 4-8-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627