

OFFICE USE ONLY  
Log No. 64904  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INVENT NO. 31577

1. OWNER Richard & Gina Gildone ADDRESS AT WELL LOCATION 1215 Argosy Road  
MAILING ADDRESS 2650 Valley View Drive Reno Nevada 89506

2. LOCATION NW 1/4 NE 1/4 Sec 19 T. 23 S. R. 19 EAST County \_\_\_\_\_  
PERMIT NO. 079-362-12 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown D.G.		0	20	
Brown sandstone		20	120	
Multi colored gravels		120	260	
Gray sand stone		260	295	
Gray volcanic rock & gray clay		295	320	
Multi colored volcanic rock		320	350	
Multi colored gravels		350	445	
T.D.		445		

8. WELL CONSTRUCTION  
Depth Drilled 445 Feet Depth Cased 445 Feet

HOLE DIAMETER (BIT SIZE)  
From To  
10 5/8 Inches 0 Feet 50 Feet  
8 1/2 Inches 50 Feet 445 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.92</u>	<u>-188</u>	<u>+1 1/2</u>	<u>445</u>

Perforations:  
Type perforation Factory Sawn  
Size perforation 3/32 x 3  
From 445 feet to 50 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 445 feet to 50 feet

9. WATER LEVEL  
Static water level 300' feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality \_\_\_\_\_

Date started July 3, 1996  
Date completed July 7, 1996

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>		<u>2 hrs.</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name A.S.A.P. Pump and Well Service Inc. Contractor  
Address 1800 1/2 Frazer Avenue Contractor  
Sparks Nevada 89431  
Nevada contractor's license number issued by the State Contractor's Board 35387-A  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509T-1  
Signed Randy Welch  
By driller performing actual drilling on site or contractor  
Date July 12, 1996