

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35298

1. OWNER Bruce Dinning ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 211042
Crescent Valley NV
 2. LOCATION SE 1/4 New 1/4 Sec. 21 T. 30 S. R. 48 E. Esuka RANCHES County _____
 PERMIT NO. _____ Parcel No. 3-08306 Subdivision Name Crescent Valley Unit #4
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP Soil		0	2	2
Cobbles		2	8	6
Clay sand		8	98	90
Clay gravel	X	98	115	17
Clay sand		115	167	52
gravel clay	X	167	194	27
Clay sand		194	200	6

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 Inches 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>0</u>	<u>200</u>

Perforations:
 Type perforation Free
 Size perforation _____
 From 100 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 97 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started Feb-21, 1997
 Date completed FEB-21, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30+</u>	<u>0</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AAA Drilling Contractor
 Address P.O. Box 10 Contractor
Elko NV
 Nevada contractor's license number issued by the State Contractor's Board 0038169
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1438
 Signed Shore Bennett
 By driller performing actual drilling on site or contractor
 Date FEB 21-97