WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64950
Permit No.
Basin 101

NOTICE OF INTENT NO. 18440

1. OWNER R. GETTO CONSRUCTION
MAILING ADDRESS 1794 TUMBLEWEED ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION
923 DRIFTWOOD

2. LOCATION SW 1/4 SE 1/4 Sec. 29 T 19N N/S R 28E E CHURCHILL County
PERMIT NO. Issued by Water Resources
008-652-52 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	19	19
BROWN CLAY		19	22	3
BROWN SAND	X	22	35	13
GREY SAND		35	50	15
BLACK SILT/CLAY		50	60	10
GREY SAND		60	73	13
BROWN CLAY		73	75	2
BROWN SAND	X	75	88	13

8. WELL CONSTRUCTION
Depth Drilled 88 Feet Depth Cased 88 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	50	Feet
6 1/8	Inches	50	Feet	88	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 7/8	12.9	.188	+1	88

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 81 feet to 86 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured

Seal Type:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 9.10 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

Date started 11/18/96, 19__
Date completed 11/20/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1 hr.

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp. (Contractor)
Address 305 E. WILLIAMS AVE. P. O. BOX 888 (Contractor)
FALLON, NV 89407

Nevada contractor's license number issued by the State Contractor's Board 11752

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996

Signed (By driller performing actual drilling on-site or contractor)

Date 12-11-96