

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 64952  
 Permit No. \_\_\_\_\_  
 Basin 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34686

1. OWNER RICH LEE CONSTRUCTION  
 MAILING ADDRESS 590 W. WILLIAMS AVENUE  
FALLON, NV 89406

ADDRESS AT WELL LOCATION  
3355 GRAYSTOKE

2. LOCATION SW 1/4 NE 1/4 Sec. 8 T 19N N/S R 29E E CHURCHILL County

PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. 10-391-11 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BROWN SAND		0	14	14
BROWN CLAY		14	16	2
BROWN SAND	X	16	30	14
GREY SAND		30	50	20
BLACK SILT		50	65	15
GREY SAND		65	75	10
GREY CLAYSILT		75	80	5
BROWN SAND	X	80	94	14

8. WELL CONSTRUCTION  
 Depth Drilled 94 Feet Depth Cased 94 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10 3/4</u> Inches	<u>0</u> Feet	<u>50</u> Feet
<u>6 1/8</u> Inches	<u>50</u> Feet	<u>94</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.9</u>	<u>.188</u>	<u>+1</u>	<u>94</u>

Perforations:  
 Type perforation MACHINE SLOT  
 Size perforation .080

From	feet to	feet
<u>87</u>	<u>92</u>	
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 5.9 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
 Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Welsco Drilling Corp. Contractor  
 Address 305 E. WILLIAMS AVE. P. O. BOX 888 Contractor  
FALLON, NV 89407

Date started 11/22/96, 19\_\_\_\_  
 Date completed 11/23/96, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>		<u>1 hr.</u>

Nevada contractor's license number issued by the State Contractor's Board 11752  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996

Signed [Signature]  
 By driller performing actual drilling on-site or contractor

Date 12-11-96