WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 64958
Permit No.
Basin 076

NOTICE OF INTENT NO. 30050

1. OWNER Dick & Diana Jones
MAILING ADDRESS 655 Helen Ct
Mantica, CA 95336

ADDRESS AT WELL LOCATION
Smithridge Lane, Fernley, NV 89408

2. LOCATION NE 1/4 SE 1/4 Sec. 27 T 20N N/S R 25E E Lyon County
PERMIT NO. _____ Issued by Water Resources | 021-481-48 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	80	80
Sand & Clay		80	280	200
Sand & Caly		280	335	55
Gravel	X	335	430	95

RECEIVED 96 NOV 21 AM 11:32 STATE ENGINEER'S OFFICE

Date started 10/7/96, 19__
Date completed 10/8/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1

8. WELL CONSTRUCTION
Depth Drilled 430 Feet Depth Cased 430 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	430 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	430

Perforations:
Type perforation Mill Cut
Size perforation 1/8
From 390 feet to 430 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 430 feet

9. WATER LEVEL
Static water level 332 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Adams
By driller performing actual drilling on-site or contractor

Date 11-19-96