

OFFICE USE ONLY
 Log No. 64962
 Permit No. _____
 Basin 085

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30648

1. OWNER MICHAEL & JENNIFER DESMOND ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 10965 Chesapeake Dr. 665 Valle Verdi Dr.
Reno, Nevada 89506 Sparks, Nevada 89436
 2. LOCATION SW 1/4 NE 1/4 Sec 20 T 21N N/S R 19-21 E Washoe County
 PERMIT NO. 076-69-027 Spanish Springs
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-------------------------------|--------------|------|-----|------------|
| Top soil | | 0 | 1 | 1 |
| Brown sandy clay with gravels | | 1 | 11 | 10 |
| Gray clay | | 11 | 14 | 3 |
| Brown sandy clay | | 14 | 43 | 29 |
| Brown sand | | 43 | 44 | 1 |
| Brown sandy clay | | 44 | 90 | 46 |
| Soft zone | | 90 | 93 | 3 |
| Brown sandy clay | | 93 | 232 | 139 |
| Gray sandy clay | | 232 | 290 | 58 |
| Soft zone | X | 290 | 294 | 4 |
| Gray clay | | 294 | 308 | 14 |
| Soft zone | X | 308 | 312 | 4 |
| Gray sandy clay | | 312 | 330 | 18 |
| Soft zone | X | 330 | 333 | 3 |
| Gray sandy clay | | 333 | 362 | 29 |
| Soft zone | X | 362 | 370 | 8 |
| Gray sandy clay | | 370 | 400 | 30 |

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 3/4 Inches 50 Feet 400 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8 | | .188 | 0 | 400 |

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 295 feet to 315 feet
 From 355 feet to 395 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 400 feet

9. WATER LEVEL
 Static water level 225 feet below land surface
 Artesian flow _____ G.P.M. 20 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, on-site driller 923
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date October 14, 1996

Date started 10-7-96, 19_____
 Date completed 10-9-96, 19_____

7. WELL TEST DATA

| TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | | | |
|---|-------------------------------|--------------|--|
| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) | |
| 20 | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

RECEIVED
 16 OCT 21 PM 2:10
 STATE WATER RESOURCES OFFICE