

OFFICE USE ONLY
 Log No. 64965
 Permit No. 284
 Basin 1

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34190

1. OWNER MIKE BROWNING ADDRESS AT WELL LOCATION 14705 State Route 445 (Pyramid Hwy)
 MAILING ADDRESS 5515 Wedekind Road Reno, Nevada 89510
Sparks, Nevada 89431
 2. LOCATION SE 1/4 SW 1/4 Sec. 24 T. 22N N/S R. 20 E Washoe County Washoe
 PERMIT NO. 076-272-08 Palomino Valley Dist. 15 24.2.8.8
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Brown volcanic rock		1	3	2
Reddish brown rock		3	9	6
Brown volcanic rock		9	39	30
Purple volcanic rock		39	44	5
Brown volcanic rock		44	88	44
Soft zone (NO WATER)		88	89	1
Brown volcanic rock		89	146	57
Light brown volcanic rock		146	181	35
Soft fracture rock	X	181	223	42
Brown volcanic rock		223	256	33
Fracture rock	X	256	269	13
Brown volcanic rock		269	275	6

8. WELL CONSTRUCTION
 Depth Drilled 275 Feet Depth Cased 275 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 275 Feet
 Inches Feet Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	275

 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 195 feet to 235 feet
 From 250 feet to 270 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 foot Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 275 feet

Date started 10-28-96, 19____
 Date completed 10-30-96, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18		

9. WATER LEVEL
 Static water level 190 feet below land surface
 Artesian flow _____ G.P.M. 18 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne C. Hedeman
 By driller performing actual drilling on site or contractor
 Date November 4, 1996