

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 5290

1. OWNER Richard Matthews ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 687 6<sup>th</sup> St JACKSON ST  
EIKU NW 89801 lot 7  
 2. LOCATION SW 1/4 NW 1/4 Sec. 15 T. 32 S. R. 55 E. EIKU County \_\_\_\_\_  
 PERMIT NO. 27-003-07-8 Parcel No. \_\_\_\_\_  
Lucky Nugget #1 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Top Soil</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>Sand + Cobbles</u>		<u>5</u>	<u>25</u>	<u>20</u>
<u>Clay with sand layer</u>	<u>x</u>	<u>35</u>	<u>104</u>	<u>69</u>
<u>Sand and gravel</u>		<u>104</u>	<u>220</u>	<u>116</u>

8. WELL CONSTRUCTION  
 Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
11 Inches 0 Feet 220 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>		<u>1 1/2</u>	<u>0</u>	<u>220</u>

Perforations:  
 Type perforation Mill Slot  
 Size perforation \_\_\_\_\_  
 From 180 feet to 220 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 5'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 5' feet to 220 feet

RECEIVED  
 96 NOV -7 AM 11:05  
 STATE ENGINEERS OFFICE

Date started 10-24, 1996  
 Date completed 10-27, 1996

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>15</u>		<u>1 1/2</u>

9. WATER LEVEL  
 Static water level 2.5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name AAA Drilling Co Contractor  
 Address Box 2487 Contractor  
EIK NW 89801  
 Nevada contractor's license number issued by the State Contractor's Board 20684  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1783  
 Signed Ray B. Ouffill  
 By driller performing actual drilling on site or contractor  
 Date 11-3-96